



Approval Certificate

Germanischer Lloyd

This is to certify, that the undernoted products have been approved in accordance with the relevant requirements of the GL Approval System.

Certificate No. 44 242 - 07 HH

Company Dynamit Nobel Defence GmbH
Dr.-Hermann-Fleck-Allee 8
57299 Burbach, GERMANY

Product Aerosol Extinguishing Generators

Type Dynameco 200-E02 and Dynameco 300-E02

Technical Data / Application

	Dynameco 200-E02	Dynameco 300-E02
--	------------------	------------------

Protected volume [m3]	2	3
Weight [kg]	0,9	1,28
Discharge time [sec]	6	8

Operating temperature range: -40°C to +85°C
Fire classes: B (limited) and C acc. to EN2

Aerosol extinguishing generators for local fire protection of electrical cabinets and switchboards up to 1000 V or similar risks.
Installed protection systems need to be provided with a fire early warning system to ensure immediate release of the aerosol extinguishing medium in the incipient stage of a fire.

Approval Standard Not defined

Documents - Approval of the Interior Ministry of Northrhine-Westfalia, certif. no. PL-4/97, with addendums 1 to 7
- Test report of test laboratory for fire protection technology of the Austrian federal fire association, No. FT 9/289/97, serial no. 127.0

Remarks Manufacturer's instructions to be observed.

Valid until 2012-01-31

Page 1 of 1

File No. XI.E.07

Hamburg, 2007-01-23

Germanischer Lloyd

Günter Hölzer

Michael Kämpf